

**PERFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION**  
**CERTIFICATE**


No ...344.....Date 13-09-2022.....

It is certified that an inspection team headed by **Aakash Sahni, Assistant Engineer, P.H.E.D, Samastipur** (Name of Officers with Designation) From **Public Health Subdivision, Samastipur** (Name of Department/Office) inspected the **DELHI PUBLIC SCHOL, MUKTAPUR, SAMASTIPUR** (Name & Address of the school) on **23.08.2022** and found that the **DELHI PUBLIC SCHOOL** (Name of School) has safe drinking water for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T Govt.

The above valid for a period of :-

**One year only**

Signature with Seal.....

  
10/09/22Name : **Aakash Sahni**

Designation :

To,

**Principal,**  
**DELHI PUBLIC SCHOOL**  
**MUKTAPUR, SAMSTIPUR**  
**Bihar-048101**

(Name &amp; Address of the Institution)

**Government of Bihar  
Public Health Engineering Department**

DISTRICT :- SAMASTIPUR

DIVISION :- SAMASTIPUR

SL. NO.	BLOCK	PANCHAYAT	VILLAGE	LOCATION OF SOURCE	PARAMETERS							REMARKS
					pH	TURB	EC	TDS	Alka.	Fe	NO <sub>3</sub>	
1	WARISNAGAR	MUKTAPUR	MUKTAPUR	DELHI PUBLIC SCHOOL	7.6	1	411	270	148	0.2	BDL	SAFE
Acceptable Limit*					6.5-8.5	1 NTU	-	500 mg/l	200 mg/l	1.0 mg/l	45mg/l	-
Permissible Limit* in absence of alternate source					NR	5 NTU	-	2000 mg/l	600 mg/l	NR	NR	-

*Bond Kumar*  
23/08/22

*Rajiv Kumar*  
23.08.22  
CHEMIST  
P.H.DIVISION, SAMASTIPUR

*CP*  
23/08/22  
Executive Engineer  
P.H. Div., Samastipur