## PERFOMA REGADING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

L 205

Date 26/06/2024

It is Certified that an Inspection team headed by AMIT KUMAR, Distric Chemist, P.H.E.D Samastipur(Name of Officers with designation) from PUBLIC HEALTH DIVISION, Samastipur(Name of department/Officer) inspected the DELHI PUBLIC SCHOOL, MUKTAPUR SAMASTIPUR(Name& Address of the school) on 19.06.2024 and found that the school DELHI PUBLIC SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/state/U.T.Govt

The above valid or a period of:- ONE YEAR

Signature with seal: ... 2

Name: .Amit..

Designation: Chemist

To

Princial,
DELHI PUBLIC SCHOOL
MUKTAPUR,SAMASTIPUR
BIHAR-848101
(Name & Address for the institution)

Principal
DELHI PUBLIC SCHOOL
MUKTAPUR. SAMASTIPUR
MUKTAPUR. SAMASTIPUR
Affiliated to CBSE. New Delhi
School Code.65175
Affiliation No. 330775

Manager
DELHI PUBLIC SCHOOL
MUKTAPUR, SAMASTIPUR
Alfiliated to CBSE, New Dolhi
School Codu-65775
Alfiliation No. 330715

0

Government of Bihar

Public Health Engineering Dep								MONTH:-JUNE 2024									
DISTRICT :- SAMASTIPUR			DIVISION :- S	T				PARAMETERS				3 3 3 3 3					REMARKS
S.N.	BLOCK	PANCHAYAT	LOCATION OF SOURCE	pH	TURB	EC	TDS	TH	Ca	CI	Mg	Alka.	S04	Fe	As	T.COLI	
1	SAMASTIPUR	MUKTAPUR	DELHI PUBLIC SCHOOL(RO)	7.7	1	98	64	32	22	17	8	50	6	0.3	0.000	-ve	360
Acceptable Limit as per BIS 10500/2012				6.5-8.5	1 NTU	-	500 mg/l	200 mg/l	75 mg/l	250m g/I	30 mg/l	200 mg/l	200 mg/l	1.0mg/l	0.01		Terretor Residuad
Permissible Limit* in absence of alternate source as per BIS 10500/2012				NR	5 NTU		2000 mg/l	600 mg/l		1000 mg/l	12.00	media -	400m g/l	NR	NR		

Principal
DELHI PUBLIC SCHOOL
MUKTAPUR, SAMASTIPUR
Affiliated to CBSE, New Delhi
Alfiliation No.330775 School Code-65775

Manager
DELHI PUBLIC SCHOOL
MUKTAPUR, SAMASTIPUR
Affiliated to CBSE, New Delhi
Affiliation Ro.-330775 School Code-65775